

**Data Form for Recording Results of  
VST Green Machine Leak Check Test**

<b>Site Information</b>	
GDF Name:	
GDF Address:	
District Permit #:	
<b>Pre-Test Procedures</b>	
Inlet and outlet valves closed for test?	<i>Comments</i>
	<input type="checkbox"/> Yes <input type="checkbox"/> No
Processor set to MANUAL OFF mode for test?	<input type="checkbox"/> Yes <input type="checkbox"/> No
VST Controller set to TEST mode (F1) for test?	<input type="checkbox"/> Yes <input type="checkbox"/> No
<b>Test Results</b>	
Test conducted at a pressure between 1.0 and 2.0 psi?	<i>Comments</i>
	<input type="checkbox"/> Yes <input type="checkbox"/> No
Leaks identified during test? <i>If yes, describe leak location and corrective action taken.</i>	<input type="checkbox"/> Yes <input type="checkbox"/> No
Leaks present at conclusion of test?	<input type="checkbox"/> Yes <input type="checkbox"/> No
<b>Post-Test Procedures</b>	
Inlet and outlet valves opened after test?	<i>Comments</i>
	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pipe plug replaced after test?	<input type="checkbox"/> Yes <input type="checkbox"/> No
Processor returned to AUTOMATIC mode after test?	<input type="checkbox"/> Yes <input type="checkbox"/> No
VST Controller set to NORMAL mode (F2) after test?	<input type="checkbox"/> Yes <input type="checkbox"/> No
<b>Technician Information</b>	
VST Certified Technician Name:	
VST Certification Number:	
Certification Expiration Date:	
Test Company:	
Date Test Conducted:	